



DEPENDENT ON TURBULENCE IN TANK AND MOUNTING ANGLE THE PROBE MAY NEED TO BE ANCHORED OR SUPPORTED.

FOR MORE INFO. SEE REFERENCE MANUAL

① P/T-RATING FOR FLANGE; SEE REF. MANUAL.

| | | | | |
|-----|------------------|-----|---|----------|
| 04 | GASKET | 1 | ACC. TO BSP-G THREAD STD. | CUSTOMER |
| 03 | GASKET | 1 | SOFT GASKET T=MIN 1.6 (ANSI B16.5/1A, EN1514-1/1BC) SEE NOTE 1 | CUSTOMER |
| 02 | SCREW/NUT/WASHER | - | ACC. TO FLANGE STD. SEE NOTE 1. | CUSTOMER |
| 01 | FLANGE | 1 | DIM. ACC. TO ANSI B 16.5/ EN 1092-1. OTHER ON REQUEST. P/T-RATING SEE NOTE 1. | RMT |
| POS | ITEM DESCRIPTION | QTY | REMARK | SUPPLIER |

| | | | | | |
|-----------------------|--------------|---------------------------------|---------------|---|------------------------|
| ISSUED BY GU-TK-RS | WEEK 0412 | PRODUCT CODE 3300 | FILE IDEAS | INSTALLATION DRAWING TITLE | |
| APPROVED BY GU-HF | WEEK 0412 | ORIGINAL DWG NO. 9150077-989 | SCALE 1:4 | MECHANICAL INSTALLATION DWG COAXIAL LEAD, SPECIAL MTRL | |
| ROSEMOUNT | | | 1 ST ANGLE | DOC TYPE 2 | DWG NO. 9150077-989 |
| | | | | ISSUE 1 | SHEET 01/01 |

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. SAAB MARINE ELECTRONICS AB.