



1/2-14 NPT CONDUIT/CABLE
 THREAD (BOTH SIDES).
 M20x1.5, PG13.5
 ADAPTERS (OPTIONAL)

1 P/T-RATING FOR FLANGE; SEE REF. MANUAL.

DEPENDENT ON TURBULENCE
 IN TANK AND MOUNTING ANGLE
 THE PROBE MAY NEED TO BE
 ANCHORED OR SUPPORTED.

FOR MORE INFO. SEE
 REFERENCE MANUAL.

POS	ITEM DESCRIPTION	QTY	REMARK	SUPPLIER
04	GASKET	1	ACC. TO BSP-G THREAD STD.	CUSTOMER
03	GASKET	1	SOFT GASKET T-MIN 1.6 (ANSI B16.5/1a, EN1514-1/1BC). SPIRAL WOUND GASKET WITH NON METALLIC FILLER (ANSI B16.5/1b, EN1514-2), SEE NOTE 1.	CUSTOMER
02	SCREW/NUT/WASHER	-	ACC. TO FLANGE STD, SEE NOTE 1.	CUSTOMER
01	FLANGE	1	DIM. ACC. TO ANSI B 16.5/EN 1092-1. OTHER ON REQUEST. P/T RATING, SEE NOTE 1.	RMT

ISSUED BY		WEEK	PRODUCT CODE	FILE	INSTALLATION DRAWING TITLE	
GU-TK-TO		0536	3300	PRO/E	MECHANICAL INSTALLATION DWG	
APPROVED BY		WEEK	ORIGINAL DWG. NO.	SCALE	COAXIAL LEAD	
GU-HF		0603	9240017-999	1:5		
ROSEMOUNT			1 ST ANGLE	DOC TYPE	DWG NO.	ISSUE SHEET
				2	9240017-999	01 1/1

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. SAAB ROSEMOUNT TANK RADAR AB.