

## ALARMAGENT PUMP STATION REPORT

RTU NAME: TRIPLEX PUMP STATION WITH PULSE FLOW METER

	PUMP 1	PUMP 2	PUMP 3
Current Run Time 1	0.0	0.0	0.0
Current Run Time 2	0.0	0.0	0.0
Hrs to Maint 1	0.0	0.0	0.0
Hrs to Maint 2	0.0	0.0	0.0

DATE	TIME	STATION FLOW MGAL	GPM			# OF STARTS			STARTS RATIO		RUNTIME HRS			RUN RATIO	
			PUMP1	PUMP2	PUMP3	PUMP1	PUMP2	PUMP3	RATIO1	RATIO2	PUMP1	PUMP2	PUMP3	RATIO1	RATIO2
Apr 13, 2005	11:38 AM	0.45	849.0	990.0	986.0	43	44	45	1.02	1.05	7.8	6.7	6.7	0.86	0.86
Apr 14, 2005	11:38 AM	0.2695	983.0	1007.0	1008.0	26	27	27	1.04	1.04	4.3	4.2	4.2	0.98	0.98
Apr 15, 2005	11:38 AM	0.4725	1021.0	995.0	1003.0	45	45	45	1.0	1.0	7.3	7.5	7.4	1.03	1.02
Apr 16, 2005	11:38 AM	0.4715	850.0	1017.0	989.0	45	46	46	1.02	1.02	8.2	6.9	7.1	0.84	0.86
Apr 17, 2005	11:38 AM	0.3135	893.0	998.0	1001.0	30	32	31	1.07	1.03	5.3	4.7	4.7	0.9	0.89

Close Window

Next RTU

Previous RTU

Select New RTU

Export Report

Show Printable Page